

## Options for protecting devices and cable specification

MODEL		FPPH30	FPPH45	FPPH60	FPPH75 (3 phase)
Breaker	Rated Current A	11	14.1	26.5	9.5
	RCD required (mA)	30	30	30	30
Fuse	A	16	16	32	16
Power Cord	(mm <sup>2</sup> )	3×2.5	3×4	3×6	5×4
Signal cable	(mm <sup>2</sup> )	3×0.5	3×0.5	3×0.5	3×0.5

### Note:

The above data is applies where the power supply is less than 10m  
 If power cord is greater than 10 m, the cable diameter must be increased.  
 The signal cable can be extended to 50m maximum.

